

**The Oriental Insurance Company Ltd.
A-25/27,Asaf Ali Road,,
New Delhi -110002**

Tender Documents

**NAME OF WORK: REPAIR AND MAINTENANCE OF
EXISTING FIRE FIGHTING ITEMS AND
SUPPLYING AND INSTALLATION OF
NEW ITEMS**

AT

**# ORIENTAL HOUSE ,A-25/27 ,
ASAF ALI ROAD , NEW DELHI**

Lead Consultants:

Vastu Mandal
Architects & Interior Designers
F-328, Lado Sarai,
New Delhi-110030
Ph 41665455 Fax 41665455
E-Mail –vastumandal@gmail.com

PART –II

FINANCIAL BID

SECTION -VI (Schedule of Quantities)						
S.NO	DESCRIPTION	UNIT	QTY	RATE (Rs)	RATE IN WORDS	AMOUNT (Rs)
1.00	Refilling of Existing portable fire extinguishers including providing wall suspension bracket, of the following type:-					
a)	CO ₂ type 2.0 Kg. capacity Fire Extinguisher including conducting the hydrotesting and recertifying the same.	Each	4			
c)	CO ₂ type 4.5 Kg. capacity Fire Extinguisher including conducting the hydrotesting and recertifying the same.	Each	12			
d)	including conducting the hydrotesting and recertifying the same.	Each	1			
2.00	Providing and fixing of new ISI marked portable fire extinguishers including wall suspension bracket /wheel trolley ,locking arrangements, pressure gauge Initial fills,delivery hose , operating manual etc of the following type:-					
a)	CO ₂ type 4.5 Kg. capacity Fire Extinguisher .flat base including valve , discharge hose of not less than 10 mm dia 1 m long and complete in all respects including initial fill wall suspension bracket and conforming to IS Code 15683 Operating Temperature :-5° C to + 55° C	Each	15			
b)	CO ₂ type 6.5 Kg. capacity Wheeled Fire Extinguisher .complete with composite trolley with handle and wheel,wheel type release valve, pressure gauge and conforming to IS Code 16018 Operating Temperature :-0(-) 30° C to + 55° C	Each	1			
c)	Water CO2 type of 9 litre Fire Extinguisher with Gun metal cap and nozzle complete in all respects including wall suspension bracket ,pressure gauge and conforming to relevant IS Code 15683 Operating Temperature :-+5° to + 55° C	Each	15			
d)	ABC Dry Powder (Stored Pressure) type of 6 Kg. Fire Extinguisher with Gun metal cap and nozzle complete in all respects including wall suspension bracket, pressure gauge and conforming to relevant IS Code 15683 with IS 14609 Operating Temperature :-(-)5° C to + 55° C	Each	18			
e)	ABC dry powder (Stored Pressure) type of 9 Kg. Fire Extinguisher with Gun metal cap and nozzle complete in all respects including wall suspension bracket, pressure gauge and conforming to IS Code 15683 with IS 14609 Operating Temperature :-30° C to + 55° C	Each	67			
f)	Mechanical Foam (AFFF) Fire extinguisher 9Litre with Gun metal cap and nozzle complete in all respects including wall suspension bracket, pressure gauge and conforming to IS Code 15683 with IS 4989 Operating Temperature :-30° C to + 55° C	Each	1			
g)	D type metal fire extinguisher of 6 Kg. Fire Extinguisher with Gun metal cap and nozzle complete in all respects including wall suspension bracket and conforming to IS Code 15683	Each	6			

S.NO	DESCRIPTION	UNIT	QTY	RATE (Rs)	RATE IN WORDS	AMOUNT (Rs)
h)	Mechanical Foam (AFFF) Type of 45 litre Fire Extinguisher with Gun metal cap and nozzle shutoff valve,complete in all respects including Trolley for mounting the Fire extinguisher and conforming to IS Code 16018 Operating Temperature :-+5C to + 55° C		2			
					TOTAL	
	Total In Words :-.....					
	Contractors Name & signature					
	Contractor stamp					